

Table of Contents

| | |
|----------------------------------|----|
| Cover Page | 1 |
| Warnings and Errors | 2 |
| Input Echo | 3 |
| XY Coordinate Calculations | 7 |
| Internal Pressure Calculations | 8 |
| External Pressure Calculations | 11 |
| Element and Detail Weights | 13 |
| Nozzle Flange MAWP | 15 |
| Natural Frequency Calculation | 16 |
| Wind/Earthquake Shear, Bending | 17 |
| Longitudinal Stress Constants | 18 |
| Longitudinal Allowable Stresses | 19 |
| Longitudinal Stresses Due to . . | 20 |
| Stress due to Combined Loads | 22 |
| Center of Gravity Calculation | 26 |
| Leg Check, (Operating Case) | 27 |
| Leg Check, (Filled w/Water) | 29 |
| Nozzle Calcs. Noz N4 | 31 |
| Nozzle Calcs. Noz N3, N2 | 34 |
| Nozzle Calcs. Noz N5, N6 | 37 |
| Nozzle Calcs. Noz N1 | 40 |
| Nozzle Schedule | 43 |
| Nozzle Summary | 44 |
| Vessel Design Summary | 45 |
| Problems/Failures Summary | 46 |

DESIGN CALCULATION

In Accordance with ASME Section VIII Division 1

ASME Code Version : 2007

Analysis Performed by : KEDKEP CONSULTING, INC.

Job File : E:\200828 AUDIT VESSEL\AUDIT VESSEL. PVI

Date of Analysis : Sep 15, 2008

PV Elite 2008, May 2008

Class From To : Basic Element Checks.

=====

Class From To: Check of Additional Element Data

=====

There were no geometry errors or warnings.

PV Elite 2008 c1993-2008 by COADE Engineering Software

PV Elite Vessel Analysis Program: Input Data

| | | |
|--|------------------|-----------|
| Design Internal Pressure (for Hydrotest) | 100.00 | psi g |
| Design Internal Temperature | 300 | F |
| Type of Hydrotest | UG99-b Note [34] | |
| Hydrotest Position | Vertical | |
| Projection of Nozzle from Vessel Top | 0.0000 | in |
| Projection of Nozzle from Vessel Bottom | 0.0000 | in |
| Minimum Design Metal Temperature | -20 | F |
| Type of Construction | Welded | |
| Special Service | None | |
| Degree of Radiography | RT-4 | |
| Miscellaneous Weight Percent | 0. | |
| Use Higher Longitudinal Stresses (Flag) | Y | |
| Select t for Internal Pressure (Flag) | N | |
| Select t for External Pressure (Flag) | N | |
| Select t for Axial Stress (Flag) | N | |
| Select Location for Stiff. Rings (Flag) | N | |
| Use Hydrotest Allowable Unmodified | Y | |
| Consider Vortex Shedding | N | |
| Perform a Corroded Hydrotest | N | |
| Is this a Heat Exchanger | No | |
| User Defined Hydro. Press. (Used if > 0) | 0.0000 | psi g |
| User defined MAWP | 0.0000 | psi g |
| User defined MAPnc | 0.0000 | psi g |
| Load Case 1 | NP+EW+WI +FW+BW | |
| Load Case 2 | NP+EW+EE+FS+BS | |
| Load Case 3 | NP+OW+WI +FW+BW | |
| Load Case 4 | NP+OW+EQ+FS+BS | |
| Load Case 5 | NP+HW+HI | |
| Load Case 6 | NP+HW+HE | |
| Load Case 7 | IP+OW+WI +FW+BW | |
| Load Case 8 | IP+OW+EQ+FS+BS | |
| Load Case 9 | EP+OW+WI +FW+BW | |
| Load Case 10 | EP+OW+EQ+FS+BS | |
| Load Case 11 | HP+HW+HI | |
| Load Case 12 | HP+HW+HE | |
| Load Case 13 | IP+WE+EW | |
| Load Case 14 | IP+WF+CW | |
| Load Case 15 | IP+VO+OW | |
| Load Case 16 | IP+VE+EW | |
| Load Case 17 | NP+VO+OW | |
| Load Case 18 | FS+BS+IP+OW | |
| Load Case 19 | FS+BS+EP+OW | |
| Wind Design Code | No Wind Loads | |
| Design Wind Speed | 70.000 | mi l e/hr |
| Exposure Constant | C | |
| Importance Factor | | |
| Roughness Factor | | |
| Base Elevation | 0.0000 | in |
| Percent Wind for Hydrotest | 33. | |
| Use Wind Profile (Y/N) | N | |
| Damping Factor (Beta) for Wind (Ope) | 0.0100 | |
| Damping Factor (Beta) for Wind (Empty) | 0.0000 | |
| Damping Factor (Beta) for Wind (Filled) | 0.0000 | |
| Sei smi c Design Code | No Sei smi c | |
| Design Nozzle for Des. Press. + St. Head | Y | |

Consider MAP New and Cold in Noz. Design N
 Consider External Loads for Nozzle Des. Y
 Consider Code Case 2168 for Nozzle Des. N

Material Database Year Current w/Addenda or Code Year

Complete Listing of Vessel Elements and Details:

Element From Node 10
 Element To Node 20
 Element Type Elliptical
 Description Bottom Head
 Distance "FROM" to "TO" 1.5000 in
 Element Outside Diameter 16.000 in
 Element Thickness 0.2250 in
 Internal Corrosion Allowance 0.0000 in
 Nominal Thickness 0.2500 in
 External Corrosion Allowance 0.0000 in
 Design Internal Pressure 100.00 psig
 Design Temperature Internal Pressure 300 F
 Design External Pressure 0.0000 psig
 Design Temperature External Pressure 200 F
 Effective Diameter Multiplier 1.2
 Material Name SA-516 70
 Allowable Stress, Ambient 20000. psi
 Allowable Stress, Operating 20000. psi
 Allowable Stress, Hydrotest 34200. psi
 Material Density 0.2830 lbm/in³
 P Number Thickness 1.2500 in
 Yield Stress, Operating 33600. psi
 UCS-66 Chart Curve Designation B
 External Pressure Chart Name CS-2
 UNS Number K02700
 Product Form Plate
 Efficiency, Longitudinal Seam 0.85
 Efficiency, Circumferential Seam 0.7
 Elliptical Head Factor 2.

Element From Node 10
 Detail Type Liquid
 Detail ID WATER
 Dist. from "FROM" Node / Offset dist -4.0000 in
 Height/Length of Liquid 5.5000 in
 Density of Liquid 62.400 lbm/ft³

Element From Node 10
 Detail Type Nozzle
 Detail ID Noz N4
 Dist. from "FROM" Node / Offset dist 0.0000 in
 Nozzle Diameter 2.5 in.
 Nozzle Schedule None
 Nozzle Class 0
 Layout Angle 0.
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.0000 lbf
 Grade of Attached Flange None
 Nozzle Matl SA-105

Element From Node 20
 Element To Node 30
 Element Type Cylinder
 Description Shell
 Distance "FROM" to "TO" 30.000 in

| | | |
|--------------------------------------|-----------|------|
| Element Outside Diameter | 16.000 | in |
| Element Thickness | 0.2500 | in |
| Internal Corrosion Allowance | 0.0000 | in |
| Nominal Thickness | 0.2500 | in |
| External Corrosion Allowance | 0.0000 | in |
| Design Internal Pressure | 100.00 | psig |
| Design Temperature Internal Pressure | 300 | F |
| Design External Pressure | 0.0000 | psig |
| Design Temperature External Pressure | 200 | F |
| Effective Diameter Multiplier | 1.2 | |
| Material Name | SA-516 70 | |
| Efficiency, Longitudinal Seam | 0.7 | |
| Efficiency, Circumferential Seam | 0.7 | |

| | | |
|--------------------------------------|--------|----------|
| Element From Node | 20 | |
| Detail Type | Liquid | |
| Detail ID | WATER | |
| Dist. from "FROM" Node / Offset dist | 0.0000 | in |
| Height/Length of Liquid | 30.000 | in |
| Density of Liquid | 62.400 | lbm/ft^3 |

| | | |
|--------------------------------------|------------|-----|
| Element From Node | 20 | |
| Detail Type | Nozzle | |
| Detail ID | Noz N3, N2 | |
| Dist. from "FROM" Node / Offset dist | 5.0000 | in |
| Nozzle Diameter | 3. | in. |
| Nozzle Schedule | None | |
| Nozzle Class | 0 | |
| Layout Angle | 270. | |
| Blind Flange (Y/N) | N | |
| Weight of Nozzle (Used if > 0) | 0.0000 | lbf |
| Grade of Attached Flange | None | |
| Nozzle Matl | SA-105 | |

| | | |
|--------------------------------------|------------|-----|
| Element From Node | 20 | |
| Detail Type | Nozzle | |
| Detail ID | Noz N5, N6 | |
| Dist. from "FROM" Node / Offset dist | 5.0000 | in |
| Nozzle Diameter | 2. | in. |
| Nozzle Schedule | 80 | |
| Nozzle Class | 150 | |
| Layout Angle | 0. | |
| Blind Flange (Y/N) | N | |
| Weight of Nozzle (Used if > 0) | 0.0000 | lbf |
| Grade of Attached Flange | GR 1.1 | |
| Nozzle Matl | SA-106 B | |

| | | |
|--------------------------------------|-------------|----|
| Element From Node | 20 | |
| Detail Type | Leg | |
| Detail ID | LEGS | |
| Dist. from "FROM" Node / Offset dist | 4.0000 | in |
| Diameter at Leg Centerline | 17.184 | in |
| Leg Orientation | 1 | |
| Number of Legs | 3 | |
| Section Identifier | L2X2X0.2500 | |
| Length of Legs | 15.500 | in |

| | | |
|--------------------------|------------|----|
| Element From Node | 30 | |
| Element To Node | 40 | |
| Element Type | Elliptical | |
| Description | Top Head | |
| Distance "FROM" to "TO" | 1.5000 | in |
| Element Outside Diameter | 16.000 | in |

Input Echo

Step: 1 5:25p Sep 15,2008

| | | |
|--------------------------------------|-----------|----------|
| Element Thickness | 0.2250 | in |
| Internal Corrosion Allowance | 0.0000 | in |
| Nominal Thickness | 0.2500 | in |
| External Corrosion Allowance | 0.0000 | in |
| Design Internal Pressure | 100.00 | psig |
| Design Temperature Internal Pressure | 300 | F |
| Design External Pressure | 0.0000 | psig |
| Design Temperature External Pressure | 200 | F |
| Effective Diameter Multiplier | 1.2 | |
| Material Name | SA-516 70 | |
| Efficiency, Longitudinal Seam | 0.85 | |
| Efficiency, Circumferential Seam | 0.7 | |
| Elliptical Head Factor | 2. | |
| | | |
| Element From Node | 30 | |
| Detail Type | Liquid | |
| Detail ID | WATER | |
| Dist. from "FROM" Node / Offset dist | 0.0000 | in |
| Height/Length of Liquid | 5.5000 | in |
| Density of Liquid | 62.400 | lbm/ft^3 |
| | | |
| Element From Node | 30 | |
| Detail Type | Nozzle | |
| Detail ID | Noz N1 | |
| Dist. from "FROM" Node / Offset dist | 0.0000 | in |
| Nozzle Diameter | 2.5 | in. |
| Nozzle Schedule | None | |
| Nozzle Class | 0 | |
| Layout Angle | 0. | |
| Blind Flange (Y/N) | N | |
| Weight of Nozzle (Used if > 0) | 0.0000 | lbf |
| Grade of Attached Flange | None | |
| Nozzle Matl | SA-105 | |

XY Coordinate Calculations

| From | To | X (Horiz.) in | Y (Vert.) in | DX (Horiz.) in | DY (Vert.) in |
|------------|----|------------------|-----------------|-------------------|------------------|
| Bottom Hea | | 0.00000 | 1.50000 | 0.00000 | 1.50000 |
| Shell | | 0.00000 | 31.5000 | 0.00000 | 30.0000 |
| Top Head | | 0.00000 | 33.0000 | 0.00000 | 1.50000 |

Element Thickness, Pressure, Diameter and Allowable Stress :

| From | To | Int. Press + Liq. Hd psi g | Nomi nal Thi ckness in | Total Corr Allowance in | El ement Di ameter in | Al lowable Stress(SE) psi |
|------------|----|----------------------------------|------------------------------|-------------------------------|-----------------------------|---------------------------------|
| Bottom Hea | | 101.481 | 0.25000 | 0.00000 | 16.0000 | 17000.0 |
| Shell | | 101.282 | 0.25000 | 0.00000 | 16.0000 | 14000.0 |
| Top Head | | 100.199 | 0.25000 | 0.00000 | 16.0000 | 17000.0 |

Element Required Thickness and MAWP :

| From | To | Desi gn Pressure psi g | M. A. W. P. Corroded psi g | M. A. P. New & Cold psi g | Actual Thi ckness in | Requi red Thi ckness in |
|------------|----|------------------------------|----------------------------------|---------------------------------|----------------------------|-------------------------------|
| Bottom Hea | | 100.000 | 489.061 | 490.542 | 0.22500 | 0.062500 |
| Shell | | 100.000 | 441.756 | 443.038 | 0.25000 | 0.062500 |
| Top Head | | 100.000 | 490.397 | 490.542 | 0.22500 | 0.062500 |
| Mi ni mum | | | 228.899 | 285.000 | | |

Note : The M. A. W. P is Governed by an ANSI Flange !

Flange MAWP including Static Pressure: 228.899 = 230.000 - 1.101 psig

Note : The M. A. P. (NC) is Governed by a Flange !

Internal Pressure Calculation Results :

ASME Code, Section VIII, Division 1, 2007

Elliptical Head From 10 To 20 SA-516 70 , UCS-66 Crv. B at 300 F

Bottom Head

Thickness Due to Internal Pressure [Tr]:

$$= (P \cdot D_o \cdot K) / (2 \cdot S \cdot E + 2 \cdot P \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (101.481 \cdot 16.0000 \cdot 1.00) / (2 \cdot 20000.00 \cdot 0.85 + 2 \cdot 101.481 \cdot (1.00 - 0.1))$$

$$= 0.0475 + 0.0000 = 0.0475 \text{ in}$$

Note: The thickness required was less than the Code Minimum, therefore the Code Minimum value of 0.0625 in will be used.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 1.481 psig

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 20000.00 \cdot 0.85 \cdot 0.2250) / (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))$$

$$= 490.542 - 1.481 = 489.061 \text{ psi g}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 20000.00 \cdot 0.85 \cdot 0.2250) / (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))$$

$$= 490.542 \text{ psi g}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (K \cdot D_o - 2 \cdot T \cdot (K - 0.1))) / (2 \cdot E \cdot t)$$

$$= (101.481 \cdot (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))) / (2 \cdot 0.85 \cdot 0.2250)$$

$$= 4137.488 \text{ psi}$$

Required Thickness of Straight Flange = 0.048 in

Percent Elongation per UCS-79 $(75 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$ 7.003 %

Min Metal Temp. w/o impact per UCS-66

Min Metal Temp. at Rqd thickness (UCS 66.1) [rat 0.24] -155 F

Cylindrical Shell From 20 To 30 SA-516 70 , UCS-66 Crv. B at 300 F

Shell

Thickness Due to Internal Pressure [Tr]:

$$= (P \cdot R_o) / (S \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (101.282 \cdot 8.0000) / (20000.00 \cdot 0.70 + 0.4 \cdot 101.282)$$

$$= 0.0577 + 0.0000 = 0.0577 \text{ in}$$

Note: The thickness required was less than the Code Minimum, therefore the Code Minimum value of 0.0625 in will be used.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 1.282 psig

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (20000.00 \cdot 0.70 \cdot 0.2500) / (8.0000 - 0.4 \cdot 0.2500)$$

$$= 443.038 - 1.282 = 441.756 \text{ psi g}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (20000.00 \cdot 0.70 \cdot 0.2500) / (8.0000 - 0.4 \cdot 0.2500)$$

$$= 443.038 \text{ psi g}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (R_o - 0.4 \cdot t)) / (E \cdot t)$$

$$= (101.282 \cdot ((8.0000 - 0.4 \cdot 0.2500)) / (0.70 \cdot 0.2500))$$

$$= 4572.156 \text{ psi}$$

Percent Elongation per UCS-79 $(50 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$ 1.587 %

Min Metal Temp. w/o impact per UCS-66 -20 F

Min Metal Temp. at Rqd thickness (UCS 66.1) [rat 0.20] -155 F

Elliptical Head From 30 To 40 SA-516 70 , UCS-66 Crv. B at 300 F

Top Head

Thickness Due to Internal Pressure [Tr]:

$$= (P \cdot D_o \cdot K) / (2 \cdot S \cdot E + 2 \cdot P \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (100.144 \cdot 16.0000 \cdot 1.00) / (2 \cdot 20000.00 \cdot 0.85 + 2 \cdot 100.144 \cdot (1.00 - 0.1))$$

$$= 0.0469 + 0.0000 = 0.0469 \text{ in}$$

Note: The thickness required was less than the Code Minimum, therefore the Code Minimum value of 0.0625 in will be used.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.144 psig

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 20000.00 \cdot 0.85 \cdot 0.2250) / (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))$$

$$= 490.542 - 0.144 = 490.397 \text{ psi g}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 20000.00 \cdot 0.85 \cdot 0.2250) / (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))$$

$$= 490.542 \text{ psi g}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (K \cdot D_o - 2 \cdot T \cdot (K - 0.1))) / (2 \cdot E \cdot t)$$

$$= (100.144 \cdot (1.00 \cdot 16.0000 - 2 \cdot 0.2250 \cdot (1.00 - 0.1))) / (2 \cdot 0.85 \cdot 0.2250)$$

$$= 4083.013 \text{ psi}$$

Required Thickness of Straight Flange = 0.047 in

Percent Elongation per UCS-79 $(75 * t_{nom} / R_f) * (1 - R_f / R_o)$ 7.003 %

Min Metal Temp. w/o impact per UCS-66 -20 F

Min Metal Temp. at Rqd thickness (UCS 66.1) [rat 0.24] -155 F

MINIMUM METAL DESIGN TEMPERATURE RESULTS :

Minimum Metal Temp. w/o impact per UCS-66 -20. F

Minimum Metal Temp. at Required thickness -155. F

Note: Heads and Shells Exempted to -20F (-29C) by paragraph UG-20F

Minimum Design Metal Temperature (Entered by User) -20. F

Hydrostatic Test Pressure Results:

Pressure per UG99b = 1.3 * M. A. W. P. * Sa/S 297.568 psi g

Pressure per UG99b[34] = 1.3 * Design Pres * Sa/S 130.000 psi g

Pressure per UG99c = 1.3 * M. A. P. - Head(Hyd) 370.500 psi g

Pressure per UG100 = 1.1 * M. A. W. P. * Sa/S 251.788 psi g

UG-99(b) Note 34, Test Pressure Calculation:

= Test Factor * Design Pressure * Stress Ratio

= 1.3 * 100.000 * 1.000

= 130.000 psi g

Vertical Hydrotest performed in accordance with: UG-99b (Note 34)

Stresses on Elements due to Hydrostatic Test Pressure:

| From To | Stress | Allowable | Ratio | Pressure |
|-------------|--------|-----------|-------|----------|
| Bottom Head | 5360.3 | 34200.0 | 0.157 | 131.47 |
| Shell | 5926.3 | 34200.0 | 0.173 | 131.28 |
| Top Head | 5308.2 | 34200.0 | 0.155 | 130.19 |

Elements Suitable for Internal Pressure.

PV Elite 2008 c1993-2008 by COADE Engineering Software

External Pressure Calculation Results :

ASME Code, Section VIII, Division 1, 2007

Elliptical Head From 10 to 20 Ext. Chart: CS-2 at 200 F

Bottom Head

Elastic Modulus from Chart: CS-2 at 300 F : 0.29000E+08 psi

Results for Maximum Allowable External Pressure (MAEP):

| | | | | |
|-------|-------|-------|-----------|----------|
| Tca | OD | D/t | Factor A | B |
| 0.225 | 16.00 | 71.11 | 0.0019531 | 14970.13 |

EMAP = B/(K0*D/t) = 14970.1309/(0.9000 *71.1111) = 233.9083 psi g

Cylindrical Shell From 20 to 30 Ext. Chart: CS-2 at 200 F

Shell

Elastic Modulus from Chart: CS-2 at 300 F : 0.29000E+08 psi

Results for Maximum Allowable External Pressure (MAEP):

| | | | | | | |
|-------|-------|-------|-------|--------|-----------|----------|
| Tca | OD | SLEN | D/t | L/D | Factor A | B |
| 0.250 | 16.00 | 35.59 | 64.00 | 2.2245 | 0.0011710 | 13053.81 |

EMAP = (4*B)/(3*(D/t)) = (4*13053.8066)/(3*64.0000) = 271.9543 psi g

Results for Maximum Stiffened Length (Slen):

| | | | | | | |
|-------|-------|----------|-------|-----------|-----------|---------|
| Tca | OD | SLEN | D/t | L/D | Factor A | B |
| 0.250 | 16.00 | 0.90E+32 | 64.00 | .5000E+02 | 0.0002686 | 3894.04 |

EMAP = (4*B)/(3*(D/t)) = (4*3894.0430)/(3*64.0000) = 81.1259 psi g

Elliptical Head From 30 to 40 Ext. Chart: CS-2 at 200 F

Top Head

Elastic Modulus from Chart: CS-2 at 300 F : 0.29000E+08 psi

Results for Maximum Allowable External Pressure (MAEP):

| | | | | |
|-------|-------|-------|-----------|----------|
| Tca | OD | D/t | Factor A | B |
| 0.225 | 16.00 | 71.11 | 0.0019531 | 14970.13 |

EMAP = B/(K0*D/t) = 14970.1309/(0.9000 *71.1111) = 233.9083 psi g

External Pressure Calculations

| From | To | Section Length in | Outside Diameter in | Corroded Thickness in | Factor A | Factor B psi |
|------|----|-------------------|---------------------|-----------------------|-----------|--------------|
| 10 | 20 | No Calc | 16.0000 | 0.22500 | 0.0019531 | 14970.1 |
| 20 | 30 | 35.5917 | 16.0000 | 0.25000 | 0.0011710 | 13053.8 |
| 30 | 40 | No Calc | 16.0000 | 0.22500 | 0.0019531 | 14970.1 |

External Pressure Calculations

| From | To | External Actual T. in | External Required T. in | External Des. Press. psi g | External M. A. W. P. psi g |
|---------|----|-----------------------|-------------------------|----------------------------|----------------------------|
| 10 | 20 | 0.22500 | No Calc | 0.00000 | 233.908 |
| 20 | 30 | 0.25000 | No Calc | 0.00000 | 271.954 |
| 30 | 40 | 0.22500 | No Calc | 0.00000 | 233.908 |
| Minimum | | | | | 233.908 |

External Pressure Calculations

| From | To | Actual Len. Bet. Stiff. in | Allow. Len. Bet. Stiff. in | Ring Inertia Required in**4 | Ring Inertia Available in**4 |
|------|----|----------------------------------|----------------------------------|-----------------------------------|------------------------------------|
| 10 | 20 | No Calc | No Calc | No Calc | No Calc |
| 20 | 30 | 35.5917 | 90.24E+30 | No Calc | No Calc |
| 30 | 40 | No Calc | No Calc | No Calc | No Calc |

Elements Suitable for External Pressure.

PV Elite 2008 c1993-2008 by COADE Engineering Software

Element and Detail Weights

| From | To | Element Metal Wgt. lbf | Element ID Volume gal | Corroded Metal Wgt. lbf | Corroded ID Volume gal | Extra due Misc % |
|-------|----|------------------------|-----------------------|-------------------------|------------------------|------------------|
| 10 | 20 | 26.4066 | 3.36386 | 26.4066 | 3.36386 | 0.00000 |
| 20 | 30 | 105.021 | 24.5054 | 105.021 | 24.5054 | 0.00000 |
| 30 | 40 | 26.4066 | 3.36386 | 26.4066 | 3.36386 | 0.00000 |
| Total | | 157 | 31 | 157 | 31 | 0 |

Weight of Details

| From | Type | Weight of Detail lbf | X Offset, Dtl. Cent. in | Y Offset, Dtl. Cent. in | Description |
|------|-------|----------------------|-------------------------|-------------------------|-------------|
| 10 | Li qd | 29.2713 | 0.00000 | -2.00000 | WATER |
| 10 | Nozl | 0.14670 | 0.00000 | 0.32396 | Noz N4 |
| 20 | Li qd | 204.416 | 0.00000 | 15.0000 | WATER |
| 20 | Nozl | 0.18667 | 9.25000 | 5.00000 | Noz N3, N2 |
| 20 | Nozl | 7.91375 | 8.75000 | 5.00000 | Noz N5, N6 |
| 20 | Legs | 12.3436 | 0.00000 | -3.75000 | LEGS |
| 30 | Li qd | 28.0187 | 0.00000 | 2.00000 | WATER |
| 30 | Nozl | 0.14670 | 0.00000 | 0.32396 | Noz N1 |

Total Weight of Each Detail Type

| | |
|-------------------------|-------|
| Total Weight of Liquid | 261.7 |
| Total Weight of Nozzles | 8.4 |
| Total Weight of Legs | 12.3 |

Sum of the Detail Weights 282.4 lbf

Weight Summary

| | |
|---|-----------|
| Fabricated Wt. - Bare Weight W/O Removable Internals | 178.6 lbf |
| Shop Test Wt. - Fabricated Weight + Water (Full) | 439.1 lbf |
| Shipping Wt. - Fab. Wt + Rem. Intls. + Shipping App. | 178.6 lbf |
| Erected Wt. - Fab. Wt + Rem. Intls. + Insul. (etc) | 178.6 lbf |
| Ope. Wt. no Liq - Fab. Wt + Intls. + Details + Wghts. | 178.6 lbf |
| Operating Wt. - Empty Wt. + Operating Liquid (No CA) | 440.3 lbf |
| Field Test Wt. - Empty Weight + Water (Full) | 439.1 lbf |
| Mass of the Upper 1/3 of the Vertical Vessel | 152.6 lbf |

Outside Surface Areas of Elements

| From | To | Surface Area in^2 |
|-------|----|------------------------------------|
| 10 | 20 | 354.871 |
| 20 | 30 | 1507.96 |
| 30 | 40 | 354.871 |
| Total | | 2217.707 in^2 [15.4 Square Feet] |

Element and Detail Weights

| From | To | Total Ele. Empty Wgt. lbf | Total. Ele. Oper. Wgt. lbf | Total. Ele. Hydro. Wgt. lbf | Total Dtl. Offset Mom. in-lb | Oper. Wgt. No Liquid lbf |
|------|------|---------------------------|----------------------------|-----------------------------|------------------------------|--------------------------|
| 10 | 20 | 26.5533 | 55.8246 | 54.6135 | 0.00000 | 26.5533 |
| 20 | Legs | 15.0829 | 42.3384 | 42.3384 | 9.46293 | 15.0829 |

| | | | | | | |
|------|---------|---------|---------|---------|---------|---------|
| Legs | 30 | 98.0390 | 275.200 | 275.200 | 61.5090 | 98.0390 |
| | 30 40 | 26.5533 | 54.5720 | 54.6135 | 0.00000 | 26.5533 |

Cumulative Vessel Weight

| From | To | Cumulative Ope Wgt. No Liquid lbm | Cumulative Oper. Wgt. lbm | Cumulative Hydro. Wgt. lbm |
|------|------|---|---------------------------------|----------------------------------|
| 10 | 20 | -26.5533 | -55.8246 | -54.6135 |
| 20 | Legs | -41.6362 | -98.1630 | -96.9520 |
| Legs | 30 | 124.592 | 329.772 | 329.813 |
| 30 | 40 | 26.5533 | 54.5720 | 54.6135 |

Note: The cumulative operating weights no liquid in the column above are the cumulative operating weights minus the operating liquid weight minus any weights absent in the empty condition.

Cumulative Vessel Moment

| From | To | Cumulative Empty Mom. in-lb | Cumulative Oper. Mom. in-lb | Cumulative Hydro. Mom. in-lb |
|------|------|-----------------------------------|-----------------------------------|------------------------------------|
| 10 | 20 | 0.00000 | 0.00000 | 0.00000 |
| 20 | Legs | 9.46293 | 9.46293 | 9.46293 |
| Legs | 30 | 61.5090 | 61.5090 | 61.5090 |
| 30 | 40 | 0.00000 | 0.00000 | 0.00000 |

Nozzle Flange MAWP Results :

| Flange Rating | Operating psi g | Ambi ent psi g | Temperature F | Cl ass | Grade Group |
|----------------|--------------------|-------------------|------------------|--------|-------------|
| ----- | 230. 000 | 285. 000 | 300 | 150 | GR 1. 1 |
| ----- | ----- | ----- | ----- | ----- | ----- |
| Minimum Rating | 230. 000 | 285. 000 | psi g | | |

Note: ANSI Ratings are per ANSI/ASME B16.5 2003 Edition

PV Elite 2008 c1993-2008 by COADE Engineering Software

The Natural Frequencies for the vessel have been computed iteratively by solving a system of matrices. These matrices describe the mass and the stiffness of the vessel. This is the generalized eigenvalue/eigenvector problem and is referenced in some mathematical texts.

The Natural Frequency for the Vessel (Empty.) is 123.297 Hz.

The Natural Frequency for the Vessel (Ope...) is 77.0974 Hz.

The Natural Frequency for the Vessel (Filled) is 77.2194 Hz.

PV Elite 2008 c1993-2008 by COADE Engineering Software

The following table is for the Operating Case.

Wind/Earthquake Shear, Bending

| From | To | Distance to Support in | Cummulative Wind Shear lbf | Earthquake Shear lbf | Wind Bending in-lb | Earthquake Bending in-lb |
|------|------|------------------------|----------------------------|----------------------|--------------------|--------------------------|
| 10 | 20 | 4.00000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 20 | Legs | 2.00000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| Legs | 30 | 13.0000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 30 | 40 | 26.0000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

Longitudinal Stress Constants

| From | To | Metal Area New & Cold in ² | Metal Area Corroded in ² | New & Cold Sect. Mod. in ³ | Corroded Sect. Mod. in ³ |
|------|----|---|---|---|---|
| 10 | 20 | 11.1507 | 11.1507 | 43.3659 | 43.3659 |
| 20 | 30 | 12.3700 | 12.3700 | 47.9580 | 47.9580 |
| 30 | 40 | 11.1507 | 11.1507 | 43.3659 | 43.3659 |

Longitudinal Allowable Stresses

| From | To | All. Str. Long. Ten. psi | All. Str. Hydr. Ten. psi | All. Str. Long. Com. psi | All. Str. Hyr. Comp. psi |
|------|------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 10 | 20 | 16800.0 | 28728.0 | -19938.3 | -24922.9 |
| 20 | Legs | 16800.0 | 28728.0 | -20216.6 | -25270.8 |
| Legs | 30 | 16800.0 | 28728.0 | -20216.6 | -25270.8 |
| 30 | 40 | 16800.0 | 28728.0 | -19938.3 | -24922.9 |

Longitudinal Stress Report

Note: Longitudinal Operating and Empty Stresses are computed in the corroded condition. Stresses due to loads in the hydrostatic test cases have been computed in the new and cold condition.

Longitudinal Stresses Due to . . .

| From | To | Long. Str. Int. Pres. psi | Long. Str. Ext. Pres. psi | Long. Str. Hyd. Pres. psi |
|------|----|---------------------------------|---------------------------------|---------------------------------|
| 10 | 20 | 1707.78 | 0.00000 | 2220.11 |
| 20 | 30 | 1530.00 | 0.00000 | 1989.00 |
| 30 | 40 | 1707.78 | 0.00000 | 2220.11 |

Longitudinal Stresses Due to . . .

| From | To | Wght. Str. Empty psi | Wght. Str. Operating psi | Wght. Str. Hydrotest psi | Wght. Str. Emp. Mom. psi | Wght. Str. Opr. Mom. psi |
|------|------|----------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 10 | 20 | 2.38131 | 5.00638 | 4.89777 | 0.00000 | 0.00000 |
| 20 | Legs | 3.36590 | 7.93556 | 7.83765 | 0.19732 | 0.19732 |
| Legs | 30 | -10.0721 | -26.6589 | -26.6623 | 1.28256 | 1.28256 |
| 30 | 40 | -2.38131 | -4.89405 | -4.89777 | 0.00000 | 0.00000 |

Longitudinal Stresses Due to . . .

| From | To | Wght. Str. Hyd. Mom. psi | Bend. Str. Oper. Wind psi | Bend. Str. Oper. Equ. psi | Bend. Str. Hyd. Wind psi | Bend. Str. Hyd. Equ. psi |
|------|------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|--------------------------------|
| 10 | 20 | 0.00000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 20 | Legs | 0.19732 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| Legs | 30 | 1.28256 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 30 | 40 | 0.00000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

Longitudinal Stresses Due to . . .

| From | To | Long. Str. Vortex Ope. psi | Long. Str. Vortex Emp. psi | Long. Str. Vortex Tst. psi | Earthquake Empty psi |
|------|------|----------------------------------|----------------------------------|----------------------------------|----------------------------|
| 10 | 20 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 20 | Legs | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| Legs | 30 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 30 | 40 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

Longitudinal Stresses Due to . . .

| From | To | Long. Str. Y Forces W psi | Long. Str. Y ForceS S psi |
|------|------|---------------------------------|---------------------------------|
| 10 | 20 | 0.00000 | 0.00000 |
| 20 | Legs | 0.00000 | 0.00000 |
| Legs | 30 | 0.00000 | 0.00000 |
| 30 | 40 | 0.00000 | 0.00000 |

Long. Stresses due to User Forces and Moments

| From | To | Wind For/Mom Corroded psi | Eqk For/Mom Corroded psi | Wnd For/Mom No Corr. psi | Eqk For/Mom No Corr. psi |
|------|------|---------------------------------|--------------------------------|--------------------------------|--------------------------------|
| 10 | 20 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| 20 | Legs | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

PV Elite 2008 Licensee: KEDKEP CONSULTING, INC.

FileName : Audit Vessel ----- Page 21 of 46

Longitudinal Stresses Due to . . . Step: 11 5:26p Sep 15,2008

| | | | | | |
|------|--------|---------|---------|---------|---------|
| Legs | 30 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |
| | 30 40 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

PV Elite 2008 c1993-2008 by COADE Engineering Software

Stress Combination Load Cases for Vertical Vessels:

Load Case Definition Key

- IP = Longitudinal Stress due to Internal Pressure
- EP = Longitudinal Stress due to External Pressure
- HP = Longitudinal Stress due to Hydrotest Pressure
- NP = No Pressure
- EW = Longitudinal Stress due to Weight (No Liquid)
- OW = Longitudinal Stress due to Weight (Operating)
- HW = Longitudinal Stress due to Weight (Hydrotest)
- WI = Bending Stress due to Wind Moment (Operating)
- EQ = Bending Stress due to Earthquake Moment (Operating)
- EE = Bending Stress due to Earthquake Moment (Empty)
- HI = Bending Stress due to Wind Moment (Hydrotest)
- HE = Bending Stress due to Earthquake Moment (Hydrotest)
- WE = Bending Stress due to Wind Moment (Empty) (no CA)
- WF = Bending Stress due to Wind Moment (Filled) (no CA)
- CW = Longitudinal Stress due to Weight (Empty) (no CA)
- VO = Bending Stress due to Vortex Shedding Loads (Ope)
- VE = Bending Stress due to Vortex Shedding Loads (Emp)
- VF = Bending Stress due to Vortex Shedding Loads (Test No CA.)
- FW = Axial Stress due to Vertical Forces for the Wind Case
- FS = Axial Stress due to Vertical Forces for the Seismic Case
- BW = Bending Stress due to Lat. Forces for the Wind Case, Corroded
- BS = Bending Stress due to Lat. Forces for the Seismic Case, Corroded
- BN = Bending Stress due to Lat. Forces for the Wind Case, UnCorroded
- BU = Bending Stress due to Lat. Forces for the Seismic Case, UnCorroded

General Notes:

Case types HI and HE are in the Un-Corroded condition.

Case types WE, WF, and CW are in the Un-Corroded condition.

A blank stress and stress ratio indicates that the corresponding stress comprising those components that did not contribute to that type of stress.

An asterisk (*) in the final column denotes overstress.

Analysis of Load Case 1 : NP+EW+WI+FW+BW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 2.38 | 16800.00 | | -19938.30 | 0.0001 | |
| 20 | 3.56 | 16800.00 | | -20216.65 | 0.0002 | |
| 20 | | 16800.00 | -11.35 | -20216.65 | | 0.0006 |
| 30 | | 16800.00 | -2.38 | -19938.30 | | 0.0001 |

Analysis of Load Case 2 : NP+EW+EE+FS+BS

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 2.38 | 16800.00 | | -19938.30 | 0.0001 | |
| 20 | 3.56 | 16800.00 | | -20216.65 | 0.0002 | |
| 20 | | 16800.00 | -11.35 | -20216.65 | | 0.0006 |
| 30 | | 16800.00 | -2.38 | -19938.30 | | 0.0001 |

Analysis of Load Case 3 : NP+OW+WI+FW+BW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |

| | | | | | | |
|----|------|----------|--------|-----------|--------|--------|
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 4 : NP+OW+EQ+FS+BS

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 5 : NP+HW+HI

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 4.90 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.03 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.90 | -19938.30 | | 0.0002 |

Analysis of Load Case 6 : NP+HW+HE

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 4.90 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.03 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.90 | -19938.30 | | 0.0002 |

Analysis of Load Case 7 : IP+OW+WI+FW+BW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1712.78 | 16800.00 | | -19938.30 | 0.1020 | |
| 20 | 1538.13 | 16800.00 | | -20216.65 | 0.0916 | |
| 20 | 1682.40 | 16800.00 | | -20216.65 | 0.1001 | |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 8 : IP+OW+EQ+FS+BS

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1712.78 | 16800.00 | | -19938.30 | 0.1020 | |
| 20 | 1538.13 | 16800.00 | | -20216.65 | 0.0916 | |
| 20 | 1682.40 | 16800.00 | | -20216.65 | 0.1001 | |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 9 : EP+OW+WI+FW+BW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 10 : EP+OW+EQ+FS+BS

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 11 : HP+HW+HI

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|

| | | | | | | |
|----|---------|----------|-------|-----------|--------|--------|
| 10 | 2225.01 | 28728.00 | | -24922.88 | 0.0775 | |
| 20 | 1997.03 | 28728.00 | | -25270.81 | 0.0695 | |
| 20 | 2194.73 | 28728.00 | | -25270.81 | 0.0764 | |
| 30 | | 28728.00 | -4.90 | -24922.88 | | 0.0002 |

Analysis of Load Case 12 : HP+HW+HE

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 2225.01 | 28728.00 | | -24922.88 | 0.0775 | |
| 20 | 1997.03 | 28728.00 | | -25270.81 | 0.0695 | |
| 20 | 2194.73 | 28728.00 | | -25270.81 | 0.0764 | |
| 30 | | 28728.00 | -4.90 | -24922.88 | | 0.0002 |

Analysis of Load Case 13 : IP+WE+EW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1710.16 | 16800.00 | | -19938.30 | 0.1018 | |
| 20 | 1533.56 | 16800.00 | | -20216.65 | 0.0913 | |
| 20 | 1698.99 | 16800.00 | | -20216.65 | 0.1011 | |
| 30 | | 16800.00 | -2.38 | -19938.30 | | 0.0001 |

Analysis of Load Case 14 : IP+WF+CW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1712.78 | 16800.00 | | -19938.30 | 0.1020 | |
| 20 | 1537.94 | 16800.00 | | -20216.65 | 0.0915 | |
| 20 | 1681.12 | 16800.00 | | -20216.65 | 0.1001 | |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 15 : IP+VO+OW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1712.78 | 16800.00 | | -19938.30 | 0.1020 | |
| 20 | 1538.13 | 16800.00 | | -20216.65 | 0.0916 | |
| 20 | 1682.40 | 16800.00 | | -20216.65 | 0.1001 | |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 16 : IP+VE+EW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1710.16 | 16800.00 | | -19938.30 | 0.1018 | |
| 20 | 1533.56 | 16800.00 | | -20216.65 | 0.0913 | |
| 20 | 1698.99 | 16800.00 | | -20216.65 | 0.1011 | |
| 30 | | 16800.00 | -2.38 | -19938.30 | | 0.0001 |

Analysis of Load Case 17 : NP+VO+OW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 18 : FS+BS+IP+OW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
| 10 | 1712.78 | 16800.00 | | -19938.30 | 0.1020 | |
| 20 | 1538.13 | 16800.00 | | -20216.65 | 0.0916 | |
| 20 | 1682.40 | 16800.00 | | -20216.65 | 0.1001 | |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Analysis of Load Case 19 : FS+BS+EP+OW

| From Node | Tensile Stress | All. Tens. Stress | Comp. Stress | All. Comp. Stress | Tens. Ratio | Comp. Ratio |
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|
|-----------|----------------|-------------------|--------------|-------------------|-------------|-------------|

| Node | Stress | Stress | Stress | Stress | Ratio | Ratio |
|------|--------|----------|--------|-----------|--------|--------|
| 10 | 5.01 | 16800.00 | | -19938.30 | 0.0003 | |
| 20 | 8.13 | 16800.00 | | -20216.65 | 0.0005 | |
| 20 | | 16800.00 | -27.94 | -20216.65 | | 0.0014 |
| 30 | | 16800.00 | -4.89 | -19938.30 | | 0.0002 |

Absolute Maximum of the all of the Stress Ratio's 0.1020

Governing Element: Bottom Head

Governing Load Case 7 : IP+OW+WI+FW+BW

PV Elite 2008 c1993-2008 by COADE Engineering Software

Shop/Field Installation Options :

Note : The CG is computed from the first Element From Node

| | |
|--|---------|
| Center of Gravity of Liquid | 16.3 in |
| Center of Gravity of Nozzles | 6.8 in |
| Center of Gravity of Legs | -2.2 in |
| Center of Gravity of Bare Shell New and Cold | 16.8 in |
| Center of Gravity of Bare Shell Corroded | 16.8 in |
| Vessel CG in the Operating Condition | 15.7 in |
| Vessel CG in the Fabricated (Shop/Empty) Condition | 15.0 in |

PV Elite 2008 c1993-2008 by COADE Engineering Software

RESULTS FOR LEGS : Operating Case Description: LEGS

Legs attached to: Shell

Section Properties : Single Angle L2X2X0.2500

USA AISC 1989 Steel Table

| | | |
|--------------------------------------|--------|-------------------------|
| Overall Leg Length | | 15.500 in |
| Effective Leg Length | Leglen | 15.500 in |
| Distance Leg Up Side of Vessel | | 4.000 in |
| Number of Legs | Nleg | 3 |
| Cross Sectional Area for L2X2X0.2500 | Aleg | 0.938 in ² |
| Section Inertia (strong axis) | | 0.348 in ⁴ |
| Section Inertia (weak axis) | | 0.348 in ⁴ |
| Section Modulus (strong axis) | | 0.247 in ⁽³⁾ |
| Section Modulus (weak axis) | | 0.247 in ⁽³⁾ |
| Radius of Gyration (strong axis) | | 0.609 in |
| Radius of Gyration (weak axis) | | 0.609 in |

Leg Orientation - Strong Axis

| | | |
|--|--------|-----------|
| Overturning Moment at top of Legs | | 0.0 in-lb |
| Total Weight Load at top of Legs | W | 427.9 lbf |
| Total Shear force at top of Legs | | 0.0 lbf |
| Additional force in Leg due to Bracing | Fadd | 0.0 lbf |
| Occasional Load Factor | Occfac | 1.000 |
| Effective Leg End Condition Factor | k | 1.000 |

Note: The Legs are Not Cross Braced
 The Leg Shear Force includes Wind and Seismic Effects

Maximum Shear at top of one Leg [Vleg]:
 = (Max(Wind, Seismic) + Fadd) * (I_{max} / I_{tot})
 = (0.0 + 0.0) * (0.3 / 1.04)
 = 0.00 lbf

Axial Compression, Leg futhest from N.A. [Sma]
 = ((W/Nleg) + (Mleg/(Nlegm*Rn))) / Aleg
 = ((427 / 3) + (0 / (1 * 9.41))) / 0.938
 = 152.07 psi

Axial Compression, Leg closest to N.A. [Sva]
 = (W / Nleg) / Aleg
 = (427 / 3) / 0.938
 = 152.07 psi

Computing Principal Axis and Inertias for Angle.

| | | | |
|----------------------------------|---------|-------------|---------|
| Leg lengths and thickness: | 2.0000 | 2.0000 | 0.25000 |
| Distance to geometric centroid: | 0.59200 | 0.59200 | |
| Arm about YY: | 0.46700 | 0.53300 | |
| Arm about ZZ: | 0.40800 | 0.46700 | |
| Leg areas: | 0.50000 | 0.43750 | |
| Geometric inertia components YY: | 0.11165 | 0.23594 | |
| Geometric inertia components ZZ: | 0.24990 | 0.97693E-01 | |
| Geometric inertias Iy & Iz: | 0.34759 | 0.34759 | |
| Product of inertia: | 0.20417 | | |
| Mohrs Radius: | 0.20417 | | |
| Average Inertia: | 0.34759 | | |

QFACT = 1.0000 FBZ = 23.760
 Principal Axis Inertias (Z&W) = 0.14342 0.55176

Angle to Principal Axis = 45.000
 Distances to extreme fibers CW & CZ = 1.4142 0.57700
 FOB from Eq 5-5 = 455.65
 Bending allowables Fby & Fbz = 23.760 23.760

Shear Center Coordinates Wo & Zo: 0.63728 0.0000

Values for Elastic Flexural-Torsional Buckling Stress:

E, G, J, RO^(2): 29500. 11346. 0.19542E-01 1.1473
 AREA, LENGTH, Kw, Kz: 0.93800 15.500 1.0000 1.0000
 H, Few, Fez, Fej: 0.64600 712.86 185.30 206.04
 Fe computed from C4-1: 183.52

Initial (Kl/r)max, & (Kl/r)equiv = 39.639 39.831
 Final (Kl/r)max, & Cc = 39.831 127.18
 Fa based on Eq 4-1 = 19.230

| | Actual | Allowable | |
|-----------------------|--------|-----------|-----|
| Weak Axis Bending : | 0.00 | 23760.00 | psi |
| Strong Axis Bending : | 0.00 | 23760.00 | psi |
| Axial Compression : | 152.07 | 19229.93 | psi |

UNITY CHECKS ARE: H1-1 0.000
 H1-2 0.000
 H1-3 0.008

AISC Unity Check : 0.008 Should be <= to 1

RESULTS FOR LEGS : HydroTest Case Description: LEGS

Legs attached to: Shell

Section Properties : Single Angle L2X2X0.2500

USA AISC 1989 Steel Table

| | | | |
|--------------------------------------|--------|--------|-------------------|
| Overall Leg Length | | 15.500 | in |
| Effective Leg Length | Leglen | 15.500 | in |
| Distance Leg Up Side of Vessel | | 4.000 | in |
| Number of Legs | Nleg | 3 | |
| Cross Sectional Area for L2X2X0.2500 | Aleg | 0.938 | in ² |
| Section Inertia (strong axis) | | 0.348 | in ⁴ |
| Section Inertia (weak axis) | | 0.348 | in ⁴ |
| Section Modulus (strong axis) | | 0.247 | in ⁽³⁾ |
| Section Modulus (weak axis) | | 0.247 | in ⁽³⁾ |
| Radius of Gyration (strong axis) | | 0.609 | in |
| Radius of Gyration (weak axis) | | 0.609 | in |

Leg Orientation - Strong Axis

| | | | |
|--|--------|-------|-------|
| Overturning Moment at top of Legs | | 0.0 | in-lb |
| Total Weight Load at top of Legs | W | 426.8 | lbf |
| Total Shear force at top of Legs | | 0.0 | lbf |
| Additional force in Leg due to Bracing | Fadd | 0.0 | lbf |
| Occasional Load Factor | Occfac | 1.000 | |
| Effective Leg End Condition Factor | k | 1.000 | |

Note: The Legs are Not Cross Braced
 The Leg Shear Force includes Wind and Seismic Effects

Maximum Shear at top of one Leg [Vleg]:
 = (Max(Wind, Seismic) + Fadd) * (I_{max} / I_{tot})
 = (0.0 + 0.0) * (0.3 / 1.04)
 = 0.00 lbf

Axial Compression, Leg futhest from N.A. [Sma]
 = ((W/Nleg) + (Mleg/(Nlegm*Rn))) / Aleg
 = ((426 / 3) + (0 / (1 * 9.41))) / 0.938
 = 151.66 psi

Axial Compression, Leg closest to N.A. [Sva]
 = (W / Nleg) / Aleg
 = (426 / 3) / 0.938
 = 151.66 psi

Computing Principal Axis and Inertias for Angle.

| | | | |
|--|---------|-------------|---------|
| Leg lengths and thickness: | 2.0000 | 2.0000 | 0.25000 |
| Distance to geometric centroid: | 0.59200 | 0.59200 | |
| Arm about YY: | 0.46700 | 0.53300 | |
| Arm about ZZ: | 0.40800 | 0.46700 | |
| Leg areas: | 0.50000 | 0.43750 | |
| Geometric inertia components YY: | 0.11165 | 0.23594 | |
| Geometric inertia components ZZ: | 0.24990 | 0.97693E-01 | |
| Geometric inertias I _y & I _z : | 0.34759 | 0.34759 | |
| Product of inertia: | 0.20417 | | |
| Mohr's Radius: | 0.20417 | | |
| Average Inertia: | 0.34759 | | |

QFACT = 1.0000 FBZ = 23.760
 Principal Axis Inertias (Z&W) = 0.14342 0.55176

Angle to Principal Axis = 45.000
 Distances to extreme fibers CW & CZ = 1.4142 0.57700
 FOB from Eq 5-5 = 455.65
 Bending allowables Fby & Fbz = 23.760 23.760

Shear Center Coordinates Wo & Zo: 0.63728 0.0000

Values for Elastic Flexural-Torsional Buckling Stress:

E, G, J, RO^(2): 29500. 11346. 0.19542E-01 1.1473
 AREA, LENGTH, Kw, Kz: 0.93800 15.500 1.0000 1.0000
 H, Few, Fez, Fej: 0.64600 712.86 185.30 206.04
 Fe computed from C4-1: 183.52

Initial (Kl/r)max, & (Kl/r)equiv = 39.639 39.831
 Final (Kl/r)max, & Cc = 39.831 127.18
 Fa based on Eq 4-1 = 19.230

| | Actual | Allowable | |
|-----------------------|--------|-----------|-----|
| Weak Axis Bending : | 0.00 | 23760.00 | psi |
| Strong Axis Bending : | 0.00 | 23760.00 | psi |
| Axial Compression : | 151.66 | 19229.93 | psi |

UNITY CHECKS ARE: H1-1 0.000
 H1-2 0.000
 H1-3 0.008


AISC Unity Check : 0.008 Should be <= to 1

INPUT VALUES, Nozzle Description: Noz N4 From : 10

| | | | |
|--|--|-----------|-------|
| Pressure for Nozzle Reinforcement Calculations P | | 101.481 | psi g |
| Temperature for Internal Pressure Temp | | 300 | F |
| Shell Material | | SA-516 70 | |
| Shell Allowable Stress at Temperature S | | 20000.00 | psi |
| Shell Allowable Stress At Ambient Sa | | 20000.00 | psi |
| Inside Diameter of Elliptical Head D | | 15.5500 | in |
| Aspect Ratio of Elliptical Head Ar | | 2.00 | |
| Head Actual Thickness T | | 0.2250 | in |
| Head Internal Corrosion Allowance Cas | | 0.0000 | in |
| Head External Corrosion Allowance Caext | | 0.0000 | in |
| Distance from Head Centerline L1 | | 0.0000 | in |
| User Entered Minimum Design Metal Temperature | | -20.00 | F |
| Nozzle Material | | SA-105 | |
| Nozzle Allowable Stress at Temperature Sn | | 20000.00 | psi |
| Nozzle Allowable Stress At Ambient Sna | | 20000.00 | psi |
| Nozzle Diameter Basis (for tr calc only) Inbase | | OD | |
| Layout Angle | | 0.00 | deg |
| Nozzle Diameter Dia | | 2.5000 | in. |
| Nozzle Size and Thickness Basis Idbn | | Actual | |
| Actual Thickness of Nozzle Thk | | 0.3000 | in |
| Nozzle Corrosion Allowance Can | | 0.0000 | in |
| Joint Efficiency of Shell Seam at Nozzle Es | | 1.00 | |
| Joint Efficiency of Nozzle Neck En | | 1.00 | |
| Nozzle Outside Projection Ho | | 0.2500 | in |
| Weld leg size between Nozzle and Pad/Shell Wo | | 0.2500 | in |
| Groove weld depth between Nozzle and Vessel Wgnv | | 0.2250 | in |
| Nozzle Inside Projection H | | 0.0000 | in |
| Weld leg size, Inside Nozzle to Shell Wi | | 0.0000 | in |
| ASME Code Weld Type per UW-16 | | C | |

The Pressure Design option was Design Pressure + static head

Nozzle Sketch



Insert Nozzle No Pad, no Inside projection

NOZZLE CALCULATION, Description: Noz N4

ASME Code, Section VIII, Division 1, 2007, UG-37 to UG-45

Actual Nozzle Outside Diameter Used in Calculation 2.500 in.

Actual Nozzle Thickness Used in Calculation 0.300 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]
 = $(P \cdot K1 \cdot D) / (2 \cdot S \cdot E - 0.2 \cdot P)$ per UG-37(a)(3)
 = $(101.48 \cdot 0.90 \cdot 15.5500) / (2 \cdot 20000.00 \cdot 1.00 - 0.2 \cdot 101.48)$
 = 0.0355 in

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot Ro) / (S \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a)(1)
 = $(101.48 \cdot 1.2500) / (20000 \cdot 1.00 + 0.4 \cdot 101.48)$
 = 0.0063 in

UG-40, Thickness and Diameter Limit Results : [Int. Press]

Effective material diameter limit, D1 3.8000 in
 Effective material thickness limit, no pad T1np 0.5625 in

Results of Nozzle Reinforcement Area Calculations:

| AREA AVAILABLE, A1 to A5 | Design | External | Mapnc |
|---------------------------|--------|----------|--------------------|
| Area Required Ar | 0.067 | NA | NA in ² |
| Area in Shell A1 | 0.360 | NA | NA in ² |
| Area in Nozzle Wall A2 | 0.147 | NA | NA in ² |
| Area in Inward Nozzle A3 | 0.000 | NA | NA in ² |
| Area in Welds A4 | 0.063 | NA | NA in ² |
| Area in Pad A5 | 0.000 | NA | NA in ² |
| TOTAL AREA AVAILABLE Atot | 0.569 | NA | NA in ² |

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Reinforcement Area Required for Nozzle [Ar]:
 = $(D1r \cdot Tr + 2 \cdot Thk \cdot Tr \cdot (1 - fr1))$ UG-37(c)
 = $(1.9000 \cdot 0.0355 + 2 \cdot (0.3000 - 0.0000) \cdot 0.0355 \cdot (1 - 1.0000))$
 = 0.067 in²

Areas per UG-37.1 but with DL = Diameter Limit, DLR = Corroded ID:

Area Available in Shell [A1]:
 = $(DL - D1r) \cdot (ES \cdot (T - Cas) - Tr) - 2 \cdot (Thk - Can) \cdot (ES \cdot (T - Cas) - Tr) \cdot (1 - fr1)$
 = $(3.800 - 1.900) \cdot (1.00 \cdot (0.2250 - 0.000) - 0.036) - 2 \cdot (0.300 - 0.000)$
 $\cdot (1.00 \cdot (0.2250 - 0.0000) - 0.0355) \cdot (1 - 1.0000)$
 = 0.360 in²

Area Available in Nozzle Wall, no Pad [A2np]:
 = $(2 \cdot \min(T1np, ho)) \cdot (Thk - Can - Trn) \cdot fr2$
 = $(2 \cdot \min(0.562, 0.250)) \cdot (0.3000 - 0.0000 - 0.0063) \cdot 1.0000$
 = 0.147 in²

Area Available in Welds, no Pad [A4np]:
 = $Wo^{(2)} \cdot fr2 + (Wi - Can / 0.707)^{(2)} \cdot fr2$
 = $0.2500^{(2)} \cdot 1.0000 + (0.0000)^{(2)} \cdot 1.0000$
 = 0.062 in²

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness per UG45(a), tra = 0.0063 in
 Wall Thickness per UG16(b), tr16b = 0.0625 in
 Wall Thickness per UG45(b)(1), trb1 = 0.0395 in
 Check UG16(b) Min. Thickness, trb1 = Max(trb1, tr16b) = 0.0625 in
 Std. Wall Pipe per UG45(b)(4), trb4 = 0.1776 in

Wall Thickness per UG45(b), trb = Min(trb1, trb4) = 0.0625 in

Final Required Thickness, tr45 = Max(tra, trb) = 0.0625 in
Available Nozzle Neck Thickness = 0.3000 in --> OK

M.A.W.P. Results for this Nozzle (Based on Areas and UG-45) at this Location
Approximate M.A.W.P. for given geometry 470.109 psig

Note: The MAWP of this junction was limited by the Areas.

Minimum Design Metal Temperature (Nozzle Neck), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F

Nozzle MDMT Thickness Calc. per UCS-66 (a)1(b), MIN(tn,t,te), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F
Minimum Temp. w/o impact per UG-20(f) -20 F

Weld Size Calculations, Description: Noz N4

Intermediate Calc. for nozzle/shell Welds Tmin 0.2500 in

Results Per UW-16.1:

Nozzle Weld Required Thickness Actual Thickness
0.1750 = 0.7 * TMIN 0.1768 = 0.7 * Woin


The Drop for this Nozzle is : 0.0552 in
The Cut Length for this Nozzle is, Drop + Ho + H + T : 0.5302 in

INPUT VALUES, Nozzle Description: Noz N3, N2 From : 20

| | | | |
|--|--------|-----------|-------|
| Pressure for Nozzle Reinforcement Calculations P | | 101.101 | psi g |
| Temperature for Internal Pressure | Temp | 300 | F |
| Shell Material | | SA-516 70 | |
| Shell Allowable Stress at Temperature | S | 20000.00 | psi |
| Shell Allowable Stress At Ambient | Sa | 20000.00 | psi |
| Inside Diameter of Cylindrical Shell | D | 15.5000 | in |
| Shell Actual Thickness | T | 0.2500 | in |
| Shell Internal Corrosion Allowance | Cas | 0.0000 | in |
| Shell External Corrosion Allowance | Caext | 0.0000 | in |
| Distance from Bottom/Left Tangent | | 6.5000 | in |
| User Entered Minimum Design Metal Temperature | | -20.00 | F |
| Nozzle Material | | SA-105 | |
| Nozzle Allowable Stress at Temperature | Sn | 20000.00 | psi |
| Nozzle Allowable Stress At Ambient | Sna | 20000.00 | psi |
| Nozzle Diameter Basis (for tr calc only) | Inbase | OD | |
| Layout Angle | | 270.00 | deg |
| Nozzle Diameter | Di a | 3.0000 | in. |
| Nozzle Size and Thickness Basis | I dbn | Actual | |
| Actual Thickness of Nozzle | Thk | 0.3125 | in |
| Nozzle Corrosion Allowance | Can | 0.0000 | in |
| Joint Efficiency of Shell Seam at Nozzle | Es | 1.00 | |
| Joint Efficiency of Nozzle Neck | En | 1.00 | |
| Nozzle Outside Projection | Ho | 0.2500 | in |
| Weld leg size between Nozzle and Pad/Shell | Wo | 0.2500 | in |
| Groove weld depth between Nozzle and Vessel | Wgnv | 0.2500 | in |
| Nozzle Inside Projection | H | 0.0000 | in |
| Weld leg size, Inside Nozzle to Shell | Wi | 0.0000 | in |
| ASME Code Weld Type per UW-16 | | C | |

The Pressure Design option was Design Pressure + static head

Nozzle Sketch



Insert Nozzle No Pad, no Inside projection

NOZZLE CALCULATION, Description: Noz N3, N2

ASME Code, Section VIII, Division 1, 2007, UG-37 to UG-45

| | | |
|--|-------|-----|
| Actual Nozzle Outside Diameter Used in Calculation | 3.000 | in. |
| Actual Nozzle Thickness Used in Calculation | 0.312 | in. |

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]
 = $(P \cdot R) / (S \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $(101.10 \cdot 7.7500) / (20000 \cdot 1.00 - 0.6 \cdot 101.10)$
 = 0.0393 in

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot R_o) / (S \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 = $(101.10 \cdot 1.5000) / (20000 \cdot 1.00 + 0.4 \cdot 101.10)$
 = 0.0076 in

UG-40, Thickness and Diameter Limit Results : [Int. Press]

Effective material diameter limit, D1 4.7500 in
 Effective material thickness limit, no pad T1np 0.6250 in

Results of Nozzle Reinforcement Area Calculations:

| AREA AVAILABLE, A1 to A5 | Design | External | Mapnc |
|---------------------------|--------|----------|--------------------|
| Area Required Ar | 0.093 | NA | NA in ² |
| Area in Shell A1 | 0.500 | NA | NA in ² |
| Area in Nozzle Wall A2 | 0.152 | NA | NA in ² |
| Area in Inward Nozzle A3 | 0.000 | NA | NA in ² |
| Area in Welds A4 | 0.063 | NA | NA in ² |
| Area in Pad A5 | 0.000 | NA | NA in ² |
| TOTAL AREA AVAILABLE Atot | 0.715 | NA | NA in ² |

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Reinforcement Area Required for Nozzle [Ar]:
 = $(D1r \cdot Tr + 2 \cdot Thk \cdot Tr \cdot (1 - fr1))$ UG-37(c)
 = $(2.3750 \cdot 0.0393 + 2 \cdot (0.3125 - 0.0000) \cdot 0.0393 \cdot (1 - 1.0000))$
 = 0.093 in²

Areas per UG-37.1 but with DL = Diameter Limit, DLR = Corroded ID:

Area Available in Shell [A1]:
 = $(DL - D1r) \cdot (ES \cdot (T - Cas) - Tr) - 2 \cdot (Thk - Can) \cdot (ES \cdot (T - Cas) - Tr) \cdot (1 - fr1)$
 = $(4.750 - 2.375) \cdot (1.00 \cdot (0.2500 - 0.000) - 0.039) - 2 \cdot (0.312 - 0.000)$
 = $(1.00 \cdot (0.2500 - 0.0000) - 0.0393) \cdot (1 - 1.0000)$
 = 0.500 in²

Area Available in Nozzle Wall, no Pad [A2np]:
 = $(2 \cdot \min(T1np, ho)) \cdot (Thk - Can - Trn) \cdot fr2$
 = $(2 \cdot \min(0.625, 0.250)) \cdot (0.3125 - 0.0000 - 0.0076) \cdot 1.0000$
 = 0.152 in²

Area Available in Welds, no Pad [A4np]:
 = $Wo^{(2)} \cdot fr2 + (Wi - Can / 0.707)^{(2)} \cdot fr2$
 = $0.2500^{(2)} \cdot 1.0000 + (0.0000)^{(2)} \cdot 1.0000$
 = 0.062 in²

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness per UG45(a), tra = 0.0076 in
 Wall Thickness per UG16(b), tr16b = 0.0625 in
 Wall Thickness per UG45(b)(1), trb1 = 0.0393 in
 Check UG16(b) Min. Thickness, trb1 = Max(trb1, tr16b) = 0.0625 in
 Std. Wall Pipe per UG45(b)(4), trb4 = 0.1890 in
 Wall Thickness per UG45(b), trb = Min(trb1, trb4) = 0.0625 in

Final Required Thickness, $tr_{45} = \text{Max}(tra, trb) = 0.0625 \text{ in}$
Available Nozzle Neck Thickness = $0.3125 \text{ in} \rightarrow \text{OK}$

M.A.W.P. Results for this Nozzle (Based on Areas and UG-45) at this Location
Approximate M.A.W.P. for given geometry 431.344 psi g

Note: The MAWP of this junction was limited by the Areas.

Minimum Design Metal Temperature (Nozzle Neck), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F

Nozzle MDMT Thickness Calc. per UCS-66 (a)1(b), MIN(tn,t,te), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F
Minimum Temp. w/o impact per UG-20(f) -20 F

Weld Size Calculations, Description: Noz N3, N2

Intermediate Calc. for nozzle/shell Welds $T_{min} = 0.2500 \text{ in}$

Results Per UW-16.1:

 Required Thickness Actual Thickness
Nozzle Weld $0.1750 = 0.7 * T_{MIN}$ $0.1768 = 0.7 * W_{o \text{ in}}$


The Drop for this Nozzle is : 0.1465 in
The Cut Length for this Nozzle is, Drop + Ho + H + T : 0.6465 in

INPUT VALUES, Nozzle Description: Noz N5, N6 From : 20

| | | | |
|--|--------|-----------|-------|
| Pressure for Nozzle Reinforcement Calculations P | | 101.101 | psi g |
| Temperature for Internal Pressure | Temp | 300 | F |
| Shell Material | | SA-516 70 | |
| Shell Allowable Stress at Temperature | S | 20000.00 | psi |
| Shell Allowable Stress At Ambient | Sa | 20000.00 | psi |
| Inside Diameter of Cylindrical Shell | D | 15.5000 | in |
| Shell Actual Thickness | T | 0.2500 | in |
| Shell Internal Corrosion Allowance | Cas | 0.0000 | in |
| Shell External Corrosion Allowance | Caext | 0.0000 | in |
| Distance from Bottom/Left Tangent | | 6.5000 | in |
| User Entered Minimum Design Metal Temperature | | -20.00 | F |
| Nozzle Material | | SA-106 B | |
| Nozzle Allowable Stress at Temperature | Sn | 17100.00 | psi |
| Nozzle Allowable Stress At Ambient | Sna | 17100.00 | psi |
| Nozzle Diameter Basis (for tr calc only) | Inbase | ID | |
| Layout Angle | | 0.00 | deg |
| Nozzle Diameter | Di a | 2.0000 | in. |
| Nozzle Size and Thickness Basis | I dbn | Nomi nal | |
| Nominal Thickness of Nozzle | Thknom | 80 | |
| Nozzle Flange Material | | SA-105 | |
| Nozzle Flange Type | | Slip on | |
| Nozzle Corrosion Allowance | Can | 0.0000 | in |
| Joint Efficiency of Shell Seam at Nozzle | Es | 1.00 | |
| Joint Efficiency of Nozzle Neck | En | 1.00 | |
| Nozzle Outside Projection | Ho | 6.0000 | in |
| Weld leg size between Nozzle and Pad/Shell | Wo | 0.2500 | in |
| Groove weld depth between Nozzle and Vessel | Wgnv | 0.2500 | in |
| Nozzle Inside Projection | H | 0.0000 | in |
| Weld leg size, Inside Nozzle to Shell | Wi | 0.0000 | in |
| ASME Code Weld Type per UW-16 | | C | |
| Class of attached Flange | | 150 | |
| Grade of attached Flange | | GR 1.1 | |

The Pressure Design option was Design Pressure + static head

Nozzle Sketch



Insert Nozzle No Pad, no Inside projection

NOZZLE CALCULATION, Description: Noz N5, N6

ASME Code, Section VIII, Division 1, 2007, UG-37 to UG-45

Actual Nozzle Inside Diameter Used in Calculation 1.939 in.
 Actual Nozzle Thickness Used in Calculation 0.218 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]
 = (P*R)/(S*E-0.6*P) per UG-27 (c) (1)
 = (101.10*7.7500)/(20000*1.00-0.6*101.10)
 = 0.0393 in

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]
 = (P*R)/(S*E-0.6*P) per UG-27 (c) (1)
 = (101.10*0.97)/(17100*1.00-0.6*101.10)
 = 0.0058 in

UG-40, Thickness and Diameter Limit Results : [Int. Press]

Effective material diameter limit, D1 3.8780 in
 Effective material thickness limit, no pad T1np 0.5450 in

Results of Nozzle Reinforcement Area Calculations:

| AREA AVAILABLE, A1 to A5 | Design | External | Mapnc |
|---------------------------|--------|----------|--------------------|
| Area Required Ar | 0.079 | NA | NA in ² |
| Area in Shell A1 | 0.395 | NA | NA in ² |
| Area in Nozzle Wall A2 | 0.198 | NA | NA in ² |
| Area in Inward Nozzle A3 | 0.000 | NA | NA in ² |
| Area in Welds A4 | 0.053 | NA | NA in ² |
| Area in Pad A5 | 0.000 | NA | NA in ² |
| TOTAL AREA AVAILABLE Atot | 0.646 | NA | NA in ² |

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Reinforcement Area Required for Nozzle [Ar]:
 = (Dl r*Tr+2*Thk*Tr*(1-fr1)) UG-37(c)
 = (1.9390*0.0393+2*(0.2180-0.0000)*0.0393*(1-0.8550))
 = 0.079 in²

Areas per UG-37.1 but with DL = Diameter Limit, DLR = Corroded ID:

Area Available in Shell [A1]:
 = (DL- Dl r) * (ES*(T-Cas) - Tr) - 2*(Thk- Can) * (ES*(T-Cas) - Tr) * (1-fr1)
 = (3.878- 1.939) * (1.00*(0.2500-0.000) - 0.039) - 2*(0.218-0.000)
 (1.00(0.2500-0.0000) - 0.0393) * (1-0.8550)
 = 0.395 in²

Area Available in Nozzle Wall, no Pad [A2np]:
 = (2 * min(T1np, ho)) * (Thk - Can - Trn) * fr2
 = (2 * min(0.545 , 6.000)) * (0.2180 - 0.0000 - 0.0058) * 0.8550)
 = 0.198 in²

Area Available in Welds, no Pad [A4np]:
 = Wo^(2) * fr2 + (Wi - Can/0.707)^(2) * fr2
 = 0.2500^(2) * 0.8550 + (0.0000)^(2) * 0.8550
 = 0.053 in²

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness per UG45(a), tra = 0.0058 in

Wall Thickness per UG16(b), tr16b = 0.0625 in
 Wall Thickness per UG45(b)(1), trb1 = 0.0393 in
 Check UG16(b) Min. Thickness, trb1 = Max(trb1, tr16b) = 0.0625 in
 Std. Wall Pipe per UG45(b)(4), trb4 = 0.1347 in
 Wall Thickness per UG45(b), trb = Min(trb1, trb4) = 0.0625 in

Final Required Thickness, tr45 = Max(trb, trb4) = 0.0625 in
 Available Nozzle Neck Thickness = .875 * 0.2180 = 0.1908 in --> OK

M.A.W.P. Results for this Nozzle (Based on Areas and UG-45) at this Location
 Approximate M.A.W.P. for given geometry 441.756 psig

Note: The MAWP of this junction was limited by the shell (minus static head).

Minimum Design Metal Temperature (Nozzle Neck), Curve: B
 Minimum Temp. w/o impact per UCS-66 -20 F
 Minimum Temp. at required thickness -155 F

Nozzle MDMT Thickness Calc. per UCS-66 (a)1(b), MIN(tn,t,te), Curve: B
 Minimum Temp. w/o impact per UCS-66 -20 F
 Minimum Temp. at required thickness -155 F
 Minimum Temp. w/o impact per UG-20(f) -20 F

ANSI Flange MDMT including temperature reduction per UCS-66.1:
 Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -20 F
 Flange MDMT with Temperature reduction per UCS-66(b)(1)(b) -55 F

Where the Temperature Reduction per UCS-66(b)(1)(b) is:
 Stress ratio, P / Ambient Rating = 101.10 / 285.00 = 0.355

Weld Size Calculations, Description: Noz N5, N6

Intermediate Calc. for nozzle/shell Welds T_{min} 0.2180 in

Results Per UW-16.1:

| | | |
|-------------|---------------------------------|----------------------------------|
| | Required Thickness | Actual Thickness |
| Nozzle Weld | 0.1526 = 0.7 * T _{MIN} | 0.1768 = 0.7 * W _o in |


The Drop for this Nozzle is : 0.0915 in
 The Cut Length for this Nozzle is, Drop + Ho + H + T : 6.3415 in

INPUT VALUES, Nozzle Description: Noz N1 From : 30

| | | | |
|--|--------|-----------|-------|
| Pressure for Nozzle Reinforcement Calculations P | | 100.000 | psi g |
| Temperature for Internal Pressure | Temp | 300 | F |
| Shell Material | | SA-516 70 | |
| Shell Allowable Stress at Temperature | S | 20000.00 | psi |
| Shell Allowable Stress At Ambient | Sa | 20000.00 | psi |
| Inside Diameter of Elliptical Head | D | 15.5500 | in |
| Aspect Ratio of Elliptical Head | Ar | 2.00 | |
| Head Actual Thickness | T | 0.2250 | in |
| Head Internal Corrosion Allowance | Cas | 0.0000 | in |
| Head External Corrosion Allowance | Caext | 0.0000 | in |
| Distance from Head Centerline | L1 | 0.0000 | in |
| User Entered Minimum Design Metal Temperature | | -20.00 | F |
| Nozzle Material | | SA-105 | |
| Nozzle Allowable Stress at Temperature | Sn | 20000.00 | psi |
| Nozzle Allowable Stress At Ambient | Sna | 20000.00 | psi |
| Nozzle Diameter Basis (for tr calc only) | Inbase | OD | |
| Layout Angle | | 0.00 | deg |
| Nozzle Diameter | Di a | 2.5000 | in. |
| Nozzle Size and Thickness Basis | I dbn | Actual | |
| Actual Thickness of Nozzle | Thk | 0.3000 | in |
| Nozzle Corrosion Allowance | Can | 0.0000 | in |
| Joint Efficiency of Shell Seam at Nozzle | Es | 1.00 | |
| Joint Efficiency of Nozzle Neck | En | 1.00 | |
| Nozzle Outside Projection | Ho | 0.2500 | in |
| Weld leg size between Nozzle and Pad/Shell | Wo | 0.2500 | in |
| Groove weld depth between Nozzle and Vessel | Wgnv | 0.2250 | in |
| Nozzle Inside Projection | H | 0.0000 | in |
| Weld leg size, Inside Nozzle to Shell | Wi | 0.0000 | in |
| ASME Code Weld Type per UW-16 | | C | |

The Pressure Design option was Design Pressure + static head

Nozzle Sketch



Insert Nozzle No Pad, no Inside projection

NOZZLE CALCULATION, Description: Noz N1

ASME Code, Section VIII, Division 1, 2007, UG-37 to UG-45

Actual Nozzle Outside Diameter Used in Calculation 2.500 in.

Actual Nozzle Thickness Used in Calculation 0.300 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]
 = $(P \cdot K1 \cdot D) / (2 \cdot S \cdot E - 0.2 \cdot P)$ per UG-37(a)(3)
 = $(100.00 \cdot 0.90 \cdot 15.5500) / (2 \cdot 20000.00 \cdot 1.00 - 0.2 \cdot 100.00)$
 = 0.0350 in

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot Ro) / (S \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a)(1)
 = $(100.00 \cdot 1.2500) / (20000 \cdot 1.00 + 0.4 \cdot 100.00)$
 = 0.0062 in

UG-40, Thickness and Diameter Limit Results : [Int. Press]

Effective material diameter limit, D1 3.8000 in
 Effective material thickness limit, no pad T1np 0.5625 in

Results of Nozzle Reinforcement Area Calculations:

| AREA AVAILABLE, A1 to A5 | Design | External | Mapnc |
|---------------------------|--------|----------|--------------------|
| Area Required Ar | 0.067 | NA | NA in ² |
| Area in Shell A1 | 0.361 | NA | NA in ² |
| Area in Nozzle Wall A2 | 0.147 | NA | NA in ² |
| Area in Inward Nozzle A3 | 0.000 | NA | NA in ² |
| Area in Welds A4 | 0.063 | NA | NA in ² |
| Area in Pad A5 | 0.000 | NA | NA in ² |
| TOTAL AREA AVAILABLE Atot | 0.570 | NA | NA in ² |

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Reinforcement Area Required for Nozzle [Ar]:
 = $(D1r \cdot Tr + 2 \cdot Thk \cdot Tr \cdot (1 - fr1))$ UG-37(c)
 = $(1.9000 \cdot 0.0350 + 2 \cdot (0.3000 - 0.0000) \cdot 0.0350 \cdot (1 - 1.0000))$
 = 0.067 in²

Areas per UG-37.1 but with DL = Diameter Limit, DLR = Corroded ID:

Area Available in Shell [A1]:
 = $(DL - D1r) \cdot (ES \cdot (T - Cas) - Tr) - 2 \cdot (Thk - Can) \cdot (ES \cdot (T - Cas) - Tr) \cdot (1 - fr1)$
 = $(3.800 - 1.900) \cdot (1.00 \cdot (0.2250 - 0.000) - 0.035) - 2 \cdot (0.300 - 0.000)$
 $\cdot (1.00 \cdot (0.2250 - 0.0000) - 0.0350) \cdot (1 - 1.0000)$
 = 0.361 in²

Area Available in Nozzle Wall, no Pad [A2np]:
 = $(2 \cdot \min(T1np, ho)) \cdot (Thk - Can - Trn) \cdot fr2$
 = $(2 \cdot \min(0.562, 0.250)) \cdot (0.3000 - 0.0000 - 0.0062) \cdot 1.0000$
 = 0.147 in²

Area Available in Welds, no Pad [A4np]:
 = $Wo^{(2)} \cdot fr2 + (Wi - Can / 0.707)^{(2)} \cdot fr2$
 = $0.2500^{(2)} \cdot 1.0000 + (0.0000)^{(2)} \cdot 1.0000$
 = 0.062 in²

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness per UG45(a), tra = 0.0062 in
 Wall Thickness per UG16(b), tr16b = 0.0625 in
 Wall Thickness per UG45(b)(1), trb1 = 0.0389 in
 Check UG16(b) Min. Thickness, trb1 = Max(trb1, tr16b) = 0.0625 in
 Std. Wall Pipe per UG45(b)(4), trb4 = 0.1776 in

Wall Thickness per UG45(b), trb = Min(trb1, trb4) = 0.0625 in

Final Required Thickness, tr45 = Max(tra, trb) = 0.0625 in
Available Nozzle Neck Thickness = 0.3000 in --> OK

M.A.W.P. Results for this Nozzle (Based on Areas and UG-45) at this Location
Approximate M.A.W.P. for given geometry 470.112 psig

Note: The MAWP of this junction was limited by the Areas.

Minimum Design Metal Temperature (Nozzle Neck), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F

Nozzle MDMT Thickness Calc. per UCS-66 (a)1(b), MIN(tn,t,e), Curve: B
Minimum Temp. w/o impact per UCS-66 -20 F
Minimum Temp. at required thickness -155 F
Minimum Temp. w/o impact per UG-20(f) -20 F

ANSI Flange MDMT including temperature reduction per UCS-66.1:
Unadjusted MDMT of ANSI B16.5/47 flanges per UCS-66(c) -20 F
Flange MDMT with Temperature reduction per UCS-66(b)(1)(b) -55 F

Where the Temperature Reduction per UCS-66(b)(1)(b) is:
Stress ratio, P / Ambient Rating = 100.00 / 285.00 = 0.351

Weld Size Calculations, Description: Noz N1

Intermediate Calc. for nozzle/shell Welds Tmin 0.2500 in

Results Per UW-16.1:

 Required Thickness Actual Thickness
Nozzle Weld 0.1750 = 0.7 * Tmin 0.1768 = 0.7 * Woin

The Drop for this Nozzle is : 0.0552 in
The Cut Length for this Nozzle is, Drop + Ho + H + T : 0.5302 in

Nozzle Schedule:

| Description | Nominal Size in. | Flange Sch/Type Cls | Noz. O/Dia in | Wall Thk in | Re-Pad ODi a in | Re-Pad Thi ck in | Cut Length in |
|-------------|------------------|---------------------|---------------|-------------|-----------------|------------------|---------------|
| Noz N5, N6 | 2.000 | 80 Slipon | 2.375 | 0.218 | - | - | 6.34 |
| Noz N4 | 2.500 | - None | 2.500 | 0.300 | - | - | 0.53 |
| Noz N1 | 2.500 | - None | 2.500 | 0.300 | - | - | 0.53 |
| Noz N3, N2 | 3.000 | - None | 3.000 | 0.312 | - | - | 0.65 |

Note on the Cut Length Calculation:

The Cut Length is the Outside Projection + Inside Projection + Drop + In Plane Shell Thickness. This value does not include weld gaps, nor does it account for shrinkage.

Please Note: In the case of Oblique Nozzles, the Outside Diameter must be increased. The Re-Pad WIDTH around the nozzle is calculated as follows:
 Width of Pad = (Pad Outside Dia. (per above) - Nozzle Outside Dia.)/2

Nozzle Material and Weld Fillet Leg Size Details:

| Nozzle | Material | Shl Grve Weld in | Noz Shl /Pad Weld in | Pad OD Weld in | Pad Grve Weld in | Inside Weld in |
|------------|----------|------------------|----------------------|----------------|------------------|----------------|
| Noz N5, N6 | SA-106 B | 0.250 | 0.250 | - | - | - |
| Noz N4 | SA-105 | 0.225 | 0.250 | - | - | - |
| Noz N1 | SA-105 | 0.225 | 0.250 | - | - | - |
| Noz N3, N2 | SA-105 | 0.250 | 0.250 | - | - | - |

Note: The Outside projections below do not include the flange thickness.

Nozzle Miscellaneous Data:

| Nozzle | Elevation/Distance From Datum in | Layout Angle deg. | Projection Outside in | Projection Inside in | Installed In Component |
|------------|----------------------------------|-------------------|-----------------------|----------------------|------------------------|
| Noz N5, N6 | 6.500 | 0.00 | 6.00 | 0.00 | Shell |
| Noz N4 | | 0.00 | 0.25 | 0.00 | Bottom Head |
| Noz N1 | | 0.00 | 0.25 | 0.00 | Top Head |
| Noz N3, N2 | 6.500 | 270.00 | 0.25 | 0.00 | Shell |

Nozzle Calculation Summary

| Description | Internal psi g | Ext | MAPNC psi g | UG45 [tr] | Weld Path | Areas |
|-------------------|-------------------|------------|----------------|-----------|--------------|--------|
| Noz N4 | 468.63 | ... | ... | OK 0.062 | OK | Passed |
| Noz N3, N2 | 430.24 | ... | ... | OK 0.062 | OK | Passed |
| Noz N5, N6 | 441.76 | ... | ... | OK 0.062 | OK | Passed |
| Noz N1 | 470.11 | ... | ... | OK 0.062 | OK | Passed |
| Min. - Nozzles | 430.24 | Noz N3, N2 | | | | |
| Min. Shell & Flgs | 228.90 | | | | | |

Computed Vessel M.A.W.P. 228.90 psi g

Note: MAWPs (Internal Case) shown above are at the High Point.

Check the Spatial Relationship between the Nozzles

| From Node | Nozzle Description | Y Coordinate, | Layout Angle, | Di a. Li mi t |
|-----------|--------------------|---------------|---------------|---------------|
| 10 | Noz N4 | 0.000 | 0.000 | 3.800 |
| 20 | Noz N3, N2 | 6.500 | 270.000 | 4.750 |
| 20 | Noz N5, N6 | 6.500 | 0.000 | 3.878 |
| 30 | Noz N1 | 0.000 | 0.000 | 3.800 |

The nozzle spacing is computed by the following:

= $\text{Sqrt}(l_l^2 + l_c^2)$ where

l_l - Arc length along the inside vessel surface in the long. direction.

l_c - Arc length along the inside vessel surface in the circ. direction

If any interferences/violations are found, they will be noted below.

No interference violations have been detected !

PV Elite 2008 c1993-2008 by COADE Engineering Software

Design Code: ASME Code Section VIII Division 1, 2007

| | | |
|---|--------------|---------------|
| Diameter Spec : | 16.000 in OD | |
| Vessel Design Length, Tangent to Tangent | | 33.00 in |
| Distance of Bottom Tangent above Grade | | 0.00 in |
| Specified Datum Line Distance | | 0.00 in |
| Shell/Head Matl | | SA-516 70 |
| Nozzle Material | | SA-105 |
| Nozzle Material | | SA-106 B |
| Internal Design Temperature | | 300 F |
| Internal Design Pressure | | 100.00 psig |
| External Design Temperature | | 0 F |
| Maximum Allowable Working Pressure | | 228.90 psig |
| External Max. Allowable Working Pressure | | 233.91 psig |
| Hydrostatic Test Pressure | | 130.00 psig |
| Required Minimum Design Metal Temperature | | -20 F |
| Warmest Computed Minimum Design Metal Temperature | | -55 F |
| Wind Design Code | | No Wind Loads |
| Earthquake Design Code | | No Seismic |

Element Pressures and MAWP: psig

| Element Desc | Internal | External | M. A. W. P | Corr. All. |
|--------------|----------|----------|------------|------------|
| Bottom Head | 101.481 | 0.000 | 489.061 | 0.0000 |
| Shell | 101.282 | 0.000 | 441.756 | 0.0000 |
| Top Head | 100.199 | 0.000 | 490.397 | 0.0000 |

Liquid Level: 41.00 in Dens.: 62.400 lbm/ft³ Sp. Gr.: 1.000

| Element Type | "To" Elev in | Length in | Element Thk in | Req'd Thk Int. | Req'd Thk Ext. | Joint Eff Long | Joint Eff Circ |
|--------------|--------------|-----------|----------------|----------------|----------------|----------------|----------------|
| Ellipse | 1.50 | 1.500 | 0.250 | 0.062 | No Calc | 0.85 | 0.70 |
| Cylinder | 31.50 | 30.000 | 0.250 | 0.062 | No Calc | 0.70 | 0.70 |
| Ellipse | 33.00 | 1.500 | 0.250 | 0.062 | No Calc | 0.85 | 0.70 |

Element thicknesses are shown as Nominal if specified, otherwise are Minimum

Note: Wind and Earthquake moments include the effects of user defined forces and moments if any exist in the job and were specified to act (compute loads and stresses) during these cases. Also included are moment effects due to eccentric weights if any are present in the input.

Weights:

| | |
|---|-----------|
| Fabricated - Bare W/O Removable Internals | 178.6 lbm |
| Shop Test - Fabricated + Water (Full) | 439.1 lbm |
| Shipping - Fab. + Rem. Intls. + Shipping App. | 178.6 lbm |
| Erected - Fab. + Rem. Intls. + Insul. (etc) | 178.6 lbm |
| Empty - Fab. + Intls. + Details + Wghts. | 178.6 lbm |
| Operating - Empty + Operating Liquid (No CA) | 440.3 lbm |
| Field Test - Empty Weight + Water (Full) | 439.1 lbm |

Listed below are the known problem areas for the current design. If one or more of the design flags are turned on, please re-run the analysis. Some of these issues may be resolved when using updated input values.

**** Warning: An ANSI Flange is limiting the MAWP and this may affect the pressure used in the Nozzle Reinforcement Calculations.**

Please review all reports carefully!

PV Elite 2008 c1993-2008 by COADE Engineering Software